

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 7300-0706:105 Page 1 of 1

CATEGORY: Misc. Device/Control Unit Accessories

LISTEE: Keltron Corporation, 225 Crescent Street, Waltham, MA 02453
Contact: Harvey Fox (781) 894-871 FAX (781) 899-9652

DESIGN: Model RF750F Subscriber Unit two way RF transceiver used with the AMSECO direct plug-in Class 2 transformer. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 120 VAC, 16.5 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as a two-way transceiver unit for use with separately listed compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details.

XLf: 7300-1516:102

09-10-03



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

SEPTEMBER 10, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager